

SAMPLE UPS EMERGENCY CALL SHEET

Service Company

Static Power

24-Hour Emergency Phone Number

410-992-7997

UPS Model Number

SUVT3500

UPS Serial Number

PD15260001215

- Call 410-992-7997 from in front of UPS. If no phone or phone service, record the following before calling;
 - Alarms with times.
 - Any lights on the front of the unit
 - Does the critical equipment have power?
 - Any unusual smells or sounds?
- Maintenance bypass is located on the wall to the left of UPS.
- Instructions for operation of UPS and Maintenance Bypass are located with this document.